



Mendocino County Health and Human Services Agency

"Healthy People, Healthy Communities"

Carmel Angelo ♦ HHSA Director

Stacey Cryer ♦ CHS Branch Director



Community Health Services Environmental Health Division

UKIAH OFFICE
501 Low Gap Rd, Room 1326
Ukiah CA 95482

Phone: 707-463-4466 Fax: 707-463-4038

FORT BRAGG OFFICE
790-A1 S Franklin St
Fort Bragg CA 95437

Phone: 707-961-2714 Fax: 707-961-2720

March 5, 2009

Mr. Chris Warrick, Chief Building Inspector
Mendocino County Planning & Building Services
501 Low Gap Rd #1440
Ukiah, CA 95482

Dear Mr. Warrick:

Subject: Brac Systems Graywater Recycling System

California Plumbing Code Section 601.1 allows fixtures to be plumbed with graywater when not deemed a concern for safety or sanitation by the Authority Having Jurisdiction. The Mendocino County Division of Environmental Health agrees to allow the installation of Brac Systems Graywater recycling system for filling and flushing toilets under a pilot project that will allow for an evaluation of the product for maintenance and water quality. Up to twelve systems can be installed, six in residential residences, and six in commercial structures. The length of the pilot project will be twelve months and will commence after the installation of the third system. Details of the study will be established with the distributor of Brac Systems.

Additionally, the Brac System as proposed is approved for use in Mendocino County under the pilot project subject to the following conditions:

1. The system shall be installed as required by the manufacturer and listing.
2. The system will be independently plumbed with no cross connection.
3. Water disinfection shall be achieved by methods other than chlorination when connected to private on site waste water treatment systems.
4. A copy of the manufacturers' installation requirements shall be provided in advance to the Chief Building Inspector.
5. Toilet water tanks shall be labeled as non-potable water.

I look forward to working with you on this project. Please contact me at 463-4466 with questions.

Sincerely,

John P. Morley, Director

Cc: Stacey Cryer
Bruce Broderick